

PAT Report Passes For all Sites and Locations

CLIENT DETAILS	
Company Name:	Hawkesbury Village Hall
Address:	High Street Hawkesbury Upton GL9 1AU



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	Glenroy Ltd
Address:	20 Siston Park Kingswood Bristol South Glos BS15 4PE
Telephone:	07971075561
Fax:	
Email:	glenroyelectrical01@hotmail.co.uk
Signature:	
Order Number:	
File Name:	Hawkesbury Village Hall August 2021.PAT

APPLIANCE DETAILS AND TEST RESULTS									
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)									
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
SITE 13HBURYHAL - LOC. 13HBURYUPT									
GUINNESS		18/06/21	P	S	S	P >99.99	S	S	PASS
01	TEAERN	20/08/21	P	S	P 0.08	P >99.99	P 0.82	P <0.10	PASS
02	KETTLE	20/08/21	P	S	P 0.10	P >99.99	P 1.94	P <0.10	PASS
02		18/06/21	P	S	S	P >99.99	S	S	PASS
03	KETTLE	20/08/21	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
04	TEAURN	20/08/21	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
05	MICROWAVE	20/08/21	P	S	P 0.08	P 9.55	P <0.05	P 0.31	PASS
06	TOASTER	20/08/21	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
07	FLOOR CLEANER	20/08/21	P	S	S	P >99.99	S	S	PASS
08	VACUME	20/08/21	P	S	S	P >99.99	S	S	PASS
09	JUICER	20/08/21	P	S	S	P >99.99	S	S	PASS
10	DISHWASHER	20/08/21	P	S	P 0.10	P 96.70	P <0.05	P 0.67	PASS
11	COFFIE MACHINE	20/08/21	P	S	P 0.07	P >99.99	P 1.56	P <0.10	PASS
12	FRIDGE	20/08/21	P	S	P 0.04	P >99.99	P <0.05	P <0.10	PASS
12	GUINNESS SHAKER	18/06/21	P	S	S	P >99.99	S	S	PASS
13	BT PHONE	18/06/21	P	S	S	P >99.99	S	S	PASS
14	FLOOR POLISHER	20/08/21	P	S	P 0.04	P >99.99	P 0.51	P 0.18	PASS
15	BEER CHILLER	20/08/21	P	S	P 0.04	P >99.99	P 0.54	P 0.11	PASS
16	ICE MACHINE	20/08/21	P	S	S	P >99.99	S	S	PASS
20	KETTLE	20/08/21	P	S	P 0.08	P >99.99	P <0.05	P <0.10	PASS
20	LEAD	20/08/21	P	P	P 0.03	P >99.99	S	S	PASS
23	FRIDGE	20/08/21	P	S	S	P >99.99	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
24	TEERN	20/08/21	P	S	P 0.08	P >99.99	P 0.57	P <0.10	PASS
25	TEAERN	20/08/21	P	S	P 0.07	P >99.99	P 1.85	P <0.10	PASS
26	SOUP WARMER	20/08/21	P	S	P 0.10	P 93.70	P <0.05	P <0.10	PASS
28	CHILLER	18/06/21	P	S	S	P >99.99	S	S	PASS
29	CHILLER	18/06/21	P	S	S	P >99.99	S	S	PASS
30	CASH TILL	18/06/21	P	S	S	P >99.99	S	S	PASS
31	DISHWASHER	20/08/21	P	S	P 0.08	P 52.28	P <0.05	P <0.10	PASS
33	PHOTO COPIER	20/08/21	P	S	S	P >99.99	S	S	PASS
36	CCTV	20/08/21	P	S	S	P >99.99	S	S	PASS
38	PC MONITOR	20/08/21	P	S	S	P >99.99	S	S	PASS
39	PC	20/08/21	P	S	S	P >99.99	S	S	PASS
40	WIFI	20/08/21	P	S	S	P >99.99	S	S	PASS
42	FRIDGE	20/08/21	P	S	P 0.10	P >99.99	P <0.05	P <0.10	PASS
45	FAN	20/08/21	P	S	S	P >99.99	S	S	PASS
46	TEAURN	20/08/21	P	S	P 0.07	P >99.99	P 1.18	P <0.10	PASS
47	TEAURN	20/08/21	P	S	P 0.10	P 4.62	P 1.58	P <0.10	PASS
48	WHISK	20/08/21	P	S	S	P >99.99	S	S	PASS
49	SLOW COOKER	20/08/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
50	SLOW COOKER	20/08/21	P	S	P 0.07	P >99.99	P <0.05	P <0.10	PASS
51	TOASTER	20/08/21	P	S	P 0.09	P >99.99	P <0.05	P <0.10	PASS
52	DOORBELL	20/08/21	P	S	S	P >99.99	S	S	PASS
53	PLUG IN TIMER	20/08/21	P	S	S	P >99.99	S	S	PASS
54	DOORBELL	20/08/21	P	S	S	P >99.99	S	S	PASS
55	DOORBELL	20/08/21	P	S	S	P >99.99	S	S	PASS
56	PHONE	20/08/21	P	S	S	P >99.99	S	S	PASS

Total Appliances > **47**

Total Appliances For Report: 47